



PURCHASE ORDER

Supplier:	POWER ACCESS ELECTRICAL SERVICES	P.O No.: 2022-09-SP-265
Address:	Tondo, Manila	Date: SEP 16 2022
Tin:	191-323-928-000	Mode of Procurement: Public bidding
Philgeps Registration	200808220811835000000	PR No.: 2022-06-786

Gentlemen:

Please furnish this Office the following articles subject to the terms and conditions contained herein:

Place of Delivery:		SPMO/ NPRCRTC		Delivery Term:	FOB Destination		
Date of Delivery:		60 calendar days upon receipt of NTP/ PO		Payment Term:	within 30 days		
Item no.	Stock/ Property No.	Unit	Description	Quantity	Unit Cost	Amount	End User
1		lot	Supply, Delivery and Installation of 1 unit Generator Set	1	1,499,000.00	1,499,000.00	NPRCRTC
			1. a. Generator: TC210TS (T2820-2009, ISO 8528) will supply 206 KVA, 3 phase but to be reconnected to single phase at 138KVA (138 kW); Brand New and 2022 manufactured; with enclosure; Diesel; application: fixed type and standby; Accessories: circuit breaker, batteries, battery charger. Standards: EN ISO 12100:2010; Passed European (CE) or American (UL) standards (with CE certification); 3650mm*1340mm*2270mm; 233kg				
			1.b. Engine: Cummins, 6CTA8.3-G2; genuine with Cummins Engine OEM certificate; Speed: 1800 RPM; Power: 187 KW minimum; compression ratio: 17:3:1; Bore and stroke: 114mm*135mm; Number of cylinders: 6 /L; Aspiration: Turbocharged and after cooled; Cooling Type: water cooled; Fuel Consumption: 44 Li/ hr				
			1.c. Alternator: Stamford; type: UCI 274F, with Stamford Alternator OEM Certificate. Thermal Insulation: Class H; Temperature Rise: Class H (163/27 °C) 206 KVA (minimum); Protection: IP 23; stator winding: double layer concentric; 2/3 winding pitch; winding leads: 12; Standard: ISO 9001 and ISO 14001 environments: Quality Assurance: BS				

Item no.	Stock/Property No.	Unit	Description	Quantity	Unit Cost	Amount	End User
			1.d. Controller: Model: DSE 6020 comply with Deep Sea Electronics Controller OEM Certificate; Digital; Fully configurable via PC and front panel configuration; Efficient power save mode; 3 phase generator sensing; 3 phase mains sensing; Power load: 3 phase generator monitoring				
			2. Automatic Transfer Switch (ATS) - Rating: 630 A, 230V, 60 Hz, single phase. Switch-gear type: changeover; quality Assurance IEC60947-6-1, GB 14048-11, with CE certification; AC-33 design; 4 patents technology; multiple safety protection function; high connection/ breaking capability. Technical Data: agreed thermal current= 630A; 1000V rated insulation voltage; 12 kV rated impulse withstand voltage; AC 440V rated voltage of the switch copper; 630A rated work current; 10le rated connection capability; 8le rated breaking capability; 70kA rated conditional short circuit current; 26kA rated short-time withstand current; 2.4S transfer time; AC 220V. Enclosure: wall-mounted- outdoor				
			3. Main Circuit Breaker (MCB) 630 A, 230V, 60 Hz, single phase; wall mounter, outdoor				
			Warranty: 1 year				
			XXXXXXXXXXXX				
				TOTAL		1,499,000.00	


(Total Amount in Words)

One million four hundred ninety nine thousand pesos only

In case of failure to make the full delivery within time specified above, a penalty of one-tenth (1/10) of one percent for every day of delay shall be imposed on the undelivered item/s.

Conforme:

Very truly yours,


ROMMEL C. NUEVO
 Signature over Printed Name of Supplier
OCTOBER 12, 2022
 Date


FELIPE SALANG COMILA
 University President

Fund Cluster: _____

ORS/BURS No.: 2022-09-0973

Funds Available: _____

Date of the ORS/BURS: SEP 20 2022

IMELDA B. GALINATO

Accountant IV
 SEP 2022

Amount: 1,499,000.00

(911)