



Republic of the Philippines
BENGUET STATE UNIVERSITY
La Trinidad, Benguet
Telefax No: 422-2176

BSU VISION: BSU as an International University engendering graduates to walk the intergenerational highways.

BSU MISSION: BSU cares to: Challenge innovation, Advance technology and facility, Revitalize administration, Engender partnership, and Serve intergenerational role.

REQUEST FOR QUOTATION (RFQ)

Company Name: _____

Address: _____

PR NO.: 2022-03-294

QUOTATION NO.: 278

Date: MAR 31 2022

ABC: PHP 1,000,000.00

The Benguet State University through its Bids and Awards Committee will undertake NP- SVP for the item/s listed below under the following terms and conditions:

- All entries must be written legibly.
- Delivery period within 30 calendar days.
- Warranty period shall be for a minimum period of three months, in case of expendable supplies, or a minimum period of one year in case of non-expendable supplies from date of acceptance of the University.
- Price validity shall be for a period of 30 calendar days.
- Bidder shall submit original brochures showing certifications of the products being offered.
- Philgeps Registration Number shall be indicated in the appropriate space below
- Deadline of submission of quotation is 3 calendar days upon receipt of RFQ.
- The item/s shall be procured by: ☒ a) line item; ☐ b) lot; ☐ c) sub-lot
- The Omnibus Sworn Statement shall be submitted upon delivery as a required supporting document for payment

REYNANTE B. BASCO
BAC Chairman

College/Dept./Office: **NPRCRTC**

Item no.	Qty	Unit	Item	Brand and Model	ABC	Unit Cost	Total Cost
1	1	lot	<p>Supply, delivery and installation of 1 unit GENERATOR</p> <p>131-135 KVA; Direct injection type with turbocharger and intercooler; 2-wire, 12-hours full tank capacity Ideal dimensions: 2m x 3m x 1.7m</p> <ul style="list-style-type: none"> Low noise, compact structure, environment friendly; Low cost, high efficiency; Heavy load durable, four-stroke, water-cooled engine Excellent transient response With Automatic Transfer Switch (ATS); overload/underload protective device and sensor; Single phase/60Hz; Voltage output: 220-240V; With stabilizer Diesel engine With free operational manual book and training on use 		1,000,000.00		
			XXXXXXXXXX				

Counter offers:

Delivery Period: _____

Warranty: _____

Price Validity: _____

We hereby submit our quotations, accept the general conditions for the above items and commit to comply with the technical specifications.

Name of Company/Supplier: _____

Signature over Printed Name: _____

Date: _____

PhilGEPS Registration No: _____

Remarks: _____